

# Missouri Department of Natural Resources



## NOTIFICATION OF PERMIT REMOVAL

Date removed: June 01, 2020

Facility Name: Bluff's Run Subdivision WWTF

Permit Number: MO-0131326

County: Stone

Facility Description: Septic tank / recirculating sand filter / chemical addition to facilitate phosphorus removal / ultraviolet disinfection / sludge disposal by contract hauler.

Design Flow: 8,100 gpd

Actual Flow: 2,000 gpd

Reason for removal: The Department has terminated Permit # MO-0131326. This facility is now operating under Missouri State Operating Permit # MO-GD00493. The Master General Permit template can be found on the Department's website at:

<https://dnr.mo.gov/env/wpp/permits/issued/docs/GD00000.pdf>.

The applicable tables for this facility are **Tables D and D-2** on Page 7 and 8 of 15. This facility is subject to the **WBC-A** limits for *E. coli*.

If you have any questions about this permit please contact Jessica Vitale at (573)-522-2575 or by email at [Jessica.Vitale@dnr.mo.gov](mailto:Jessica.Vitale@dnr.mo.gov).